



Ref. Certif. No.

SE-112657

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product Circuit-breakers for over current protection for household and similar installations

Name and address of the applicant Siemens Electrical Apparatus Ltd. Suzhou
No.455 Zhujiang Road, Suzhou New District, 215129
Suzhou, China

Name and address of the manufacturer Same as applicant

Name and address of the factory

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics See page 2

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used -

Model / Type Ref. ATH6-63****

Additional information (if necessary may also be reported on page 2) Additional Information on page 2

A sample of the product was tested and found to be in conformity with IEC 60898-1:2015+A1

As shown in the Test Report Ref. No. which forms part of this Certificate 231100130SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden

Date: 28 November, 2023

intertek

Signature:

Fredrik Wennersten

Ratings and principal characteristics

Un= 230V~(1P), 400V~ (2P, 3P, 4P), 50/60Hz

In= 1, 2, 4, 6, 10, 16, 20, 25, 32, 40, 50, 63A(ATH6-63N***, Icn= Ics= 6000A)

In=50, 63A(ATH6-63A***, Icn= Ics= 4500A),

C-, D- type

Additional information

Explanation of type designation ATH6-63****:

ATH 6 - 63 * * * *
a) b) c) d) e) f) g)

- a) series: ATH
- b) product name: 6 means MCB
- c) frame grade: 63 means 63A
- d) breaking capacity: A: 4,5kA; N: 6kA
- e) number of pole: 1 means 1P, 2 means 2P, 3 means 3P, 4 means 4P
- f) tripping type: C means C type, D mean D type
- g) rated current(A): 1, 2, 4, 6, 10, 16, 20, 25, 32, 40, 50, 63

Date: 28 November, 2023

Signature: 