



Ref. Certif. No.

CN47467

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Relay

Name and address of the applicant

Siemens Electrical Apparatus Ltd., Suzhou  
No.455 Zhujiang Road, New District, Suzhou, Jiangsu Province, P.R.China

Name and address of the manufacturer

Siemens Electrical Apparatus Ltd., Suzhou  
No.455 Zhujiang Road, New District, Suzhou, Jiangsu Province, P.R.China

Name and address of the factory

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Contact loads: PR: 15A, 12A, 10A; ER,NR,HR: 10A, 7A, 6.5A, 5A, 3A; 277VAC/250VAC/240VAC/30VDC/28VDC; Coil voltage: 6VDC, 9VDC, 12VDC, 24VDC, 36VDC, 48VDC, 110VDC, 125VDC, 220VDC; 6VAC, 9VAC, 12VAC, 24VAC, 36VAC, 48VAC, 110VAC, 125VAC, 220VAC, 230VAC, 240VAC, 380VAC; 0.9W, 1.2VA; Electrical endurance: 10000 cycle(15A); 120000 cycle(12A, 10A, 7A, 6.5A, 5A, 3A); Mechanical endurance: 20000000 cycle; Ambient temperature: -40°C~85°C; RT I

Trademark (if any)

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

ER,NR,HR,PR series

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 61810-1:2015

As shown in the Test Report Ref. No. which forms part of this Certificate

CVC2019-0593

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China  
Tel: +86-10-83886666 Fax: +86-10-83886282  
website: http://www.cqc.com.cn



Date: Jul.16,2019

Signature:

Lu Mei

CB 0050896