

**IEC****IECEE**

®

TM

Ref. Certif. No.

CN62908

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Pushbutton

Name and address of the applicant

Siemens Electrical Apparatus Ltd., Suzhou  
No.455 Zhujiang Road, New District, Suzhou, Jiangsu  
Province, P.R.China

Name and address of the manufacturer

Siemens Electrical Apparatus Ltd., Suzhou  
No.455 Zhujiang Road, New District, Suzhou, Jiangsu  
Province, P.R.China

Name and address of the factory

Siemens Electrical Apparatus Ltd., Suzhou, Tiantai Branch  
No.699-10, Jigong Road, Tiantai County, Zhejiang  
Province, P.R.China*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

See the Appendix

Trademark / Brand (if any)

APT

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

LA39-C;

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-5-1:2016(4th Edition)

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2023CQC-108724

This CB Test Certificate is issued by the National Certification Body

**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Nov.07,2023

Signature:

谢肇煦

Xie ZhaoXu

**CB 0074555**



LA39-C

Ui:660V;

Uimp:4kV;

Ith:10A;

Momentary action:

AC-15:Ue/Ie:24V/10A,48V/10A,110V/5A,220V/2.5A,380V/1.5A ,660V/0.8A;

DC-13:Ue/Ie:24V/3.6A,48V/1.8A,110V/0.8A,220V/0.4A,440V/0.2A

Squirm action:

AC-15:Ue/Ie:24V/10A ,48V/10A ,110V/10A ,220V/6A ,380V/4A ,660V/2A;

DC-13:Ue/Ie:24V/6A,48V/3A,110V/1A,220V/0.5A,440V/0.25A;

Φ 30mm.

Except ZY (key reset emergency stop button), head with RV at the end, JY, JYS, KY, KYS with 38 at the end are IP40,

The rest of the s (general button, D, T, TD, M, MT, MD, MTD, Z, Y, YS, X, XS, CX, CXS, XD, XSD, JY, JYS, KY, KYS, LY, LYS, NY, NYS, MY, MYS is IP54,

Where X, XS, CX, CXS, JY, JYS, KY, KYS can be custom-made IP65).

Page 1 of 1

Additional information (if necessary)

Date: Nov.07,2023

Signature:

谢肇煦

Xie ZhaoXu