

IEC**IECEE**

Ref. Certif. No.

CN57410

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Relay

Name and address of the applicant

Siemens Electrical Apparatus Ltd., Suzhou
No.455 Zhujiang Road, New District, Suzhou, Jiangsu Province,
P.R.China

Name and address of the manufacturer

Siemens Electrical Apparatus Ltd., Suzhou
No.455 Zhujiang Road, New District, Suzhou, Jiangsu Province,
P.R.China

Name and address of the factory

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

2-pole: 12 : A 250VAC/30VDC; 4-pole: 6A 250VAC/30VDC; Coil
voltage: 5VDC, 6VDC, 12VDC, 24VDC, 36VDC, 48VDC, 110VDC, 220VDC 1.2W;
6VAC, 12VAC, 24VAC, 36VAC, 48VAC, 110VAC, 220VAC, 240VAC, 1.2VA; Electrical endurance: 120000 cycles.
Mechanical endurance 20000000 cycles, Ambient temperature: -40°C~85°C, RT I

Trademark / Brand (if any)

See Annex

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

NR Series

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 61810-1:2015

As shown in the Test Report Ref. No. which forms part of this Certificate

CVC2022-0576

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date:

Jul.13,2022

Signature:

谢肇旭

Xie ZhaoXu



CB 0069614

IEC

IECEE

Ref. Certif. No.

CN57410

APT

Page 1 of 1

Additional information (if necessary)

Date: Jul.13,2022

Signature:

谢肇煦

Xie ZhaoXu